

Drain Body: 200C3

NSF Report: J-00259276

Standard Cover and Vertical Pipe

Flow rate (gpm)	Water level (in)			Down pipe pressure (in H2O)		
	Avg	Min	Max	Avg	Min	Max
38	0.97	0.95	0.98	-0.28	-0.41	-0.22
159	1.92	1.90	1.97	-9.07	-12.59	-7.85
219	2.24	2.22	2.28	-19.38	-21.13	-17.78
247	2.86	2.59	3.19	-24.36	-32.11	-12.82
259	4.00	3.28	4.24	-28.01	-51.35	-18.95
339	4.35	4.10	4.52	-63.18	-70.52	-31.94
446	4.89	4.78	5.05	-72.54	-75.57	-69.73
473	6.00	5.48	6.45	-75.43	-76.95	-72.40

Post-test residual water: 1/4"

Standard Cover and Offset Pipe

Flow rate (gpm)	Water level (in)			Down pipe pressure (in H2O)		
	Avg	Min	Max	Avg	Min	Max
38	0.91	0.91	0.93	-0.47	-0.66	-0.32
161	1.85	1.83	1.88	-17.00	-21.32	-13.39
221	2.22	2.22	2.25	-28.87	-31.23	-25.64
248	2.96	2.96	3.06	-34.03	-38.50	-28.74
256	4.29	4.29	4.39	-34.25	-38.33	-30.02
327	4.47	4.47	4.62	-64.17	-70.51	-51.53
387	4.99	4.99	5.11	-74.11	-75.48	-72.11
398	6.71	6.19	7.12	-73.31	-75.25	-71.75

Post-test residual water: 1/4"