

**Drain Body: 200C5**

**NSF Report: J-00259278**

**Standard Cover and Vertical Pipe**

Flow rate (gpm)	Water level (in)			Down pipe pressure (in H2O)		
	Avg	Min	Max	Avg	Min	Max
51	0.89	0.14	1.02	-0.60	-0.80	-0.15
198	1.90	1.88	1.92	-4.72	-5.68	-4.12
277	3.28	3.18	3.46	4.62	3.93	5.14
318	4.04	2.74	4.62	-4.65	-44.12	3.61
396	4.29	3.32	5.15	-14.74	-53.57	2.49
494	4.42	3.51	5.61	-20.84	-56.88	1.03
611	3.30	3.28	3.35	-21.60	-24.55	-24.55
905	4.09	4.05	4.16	-40.38	-48.37	-38.48
1153	5.14	4.93	5.27	-57.71	-62.42	-52.69
1171	5.56	5.07	6.15	-62.97	-64.64	-55.64

Post-test residual water: 1/4"

**Standard Cover and Offset Pipe**

Flow rate (gpm)	Water level (in)			Down pipe pressure (in H2O)		
	Avg	Min	Max	Avg	Min	Max
53	1.07	1.06	1.07	-0.68	-0.96	-0.45
221	2.03	2.00	2.05	-7.61	-9.31	-6.08
570	3.23	3.19	3.27	-38.12	-46.57	-26.37
739	4.22	3.89	4.54	-42.14	-48.16	-24.65
1005	6.26	5.30	6.95	-47.95	-49.30	-46.24

Post-test residual water: 1/4"