

Drain Body: 200C6
NSF Report: J-00259279

Standard Cover and Vertical Pipe

Flow rate (gpm)	Water level (in)			Down pipe pressure (in H2O)		
	Avg	Min	Max	Avg	Min	Max
71	0.96	0.94	0.99	-0.11	-0.22	-0.03
298	1.85	1.81	1.88	-1.56	-1.77	-1.37
557	2.58	2.54	2.63	-3.21	-6.34	-1.36
965	3.39	3.34	3.45	-8.91	-9.75	-7.59
1489	4.97	4.93	5.00	-35.45	-35.72	-35.00
1746	6.54	6.33	6.64	-38.89	-39.21	-38.05

Post-test residual water: 1/8"

Standard Cover and Offset Pipe

Flow rate (gpm)	Water level (in)			Down pipe pressure (in H2O)		
	Avg	Min	Max	Avg	Min	Max
39	0.89	0.88	0.90	-1.32	-1.72	-0.85
234	2.05	1.94	2.16	-5.52	-7.61	-3.96
525	2.95	2.90	2.99	-22.06	-26.81	-17.64
946	3.99	3.94	4.04	-47.74	-55.43	-45.12
1440	4.96	4.92	5.00	-54.22	-54.91	-53.41
1541	5.85	5.68	5.99	-56.07	-57.09	-54.71
1554	6.30	6.13	6.41	-56.08	-56.63	-55.11

Post-test residual water: 1/8"