

Froet Drain Strainer Free Area					
Drain size	IPC free area requirement in. ²	ASME A112.6.4-2003 free area in. ²	Froet Drain 3" high primary strainer free area in. ²	Froet Drain 5" high primary strainer free area in. ²	Froet Drain secondary strainer free area in. ²
2"	4.71	18	30	48	73
3"	10.59	25	62	90	105
4"	18.84	36	62	90	105
5"	28.87	50	95	127	146
6"	43.31	70	95	127	146
8"	75.36	NA	163	203	200